

300213-80000428 III.1



1947 Settrington Dr
Kingsville Ontario N9Y 2E5
226-270-0074



Enclosure Type 12

ENCLOSURE OPENINGS ARE TO BE FILLED WITH EQUIPMENT MARKED FOR USE IN THE SAME ENVIRONMENT TYPE AS THE ENCLOSURE.

CONDUIT INSTALLATION: Use watertight hubs which are UL/CSA approved. When selecting the location, make sure adequate wire bending space is provided, as well as a flat, smooth surface to permit proper installation.

APPROVED FOR USE WITH INDUSTRIAL CONTROL EQUIPMENT ONLY

Serial Number:

Date: